



DELAWARE COUNTY REGIONAL WATER QUALITY CONTROL AUTHORITY
P.O. Box 999 • Chester, PA 19016-0999

WASTEWATER DISCHARGE PERMIT
Permit No. 2DC-06-01
FINAL

In accordance with the provisions of the DELCORA Standards, Rules, and Regulations of 2011, Resolution No. 2011-04 and Resolution No. 2013-12 Establishing Local Limits for Discharge to DELCORA Facilities Under the Industrial Pretreatment Program, or as Amended,

Sunoco Logistics Partners L.P. ("Permittee")
Calcon Hook and Hook Roads
Darby, Pennsylvania 19023

is hereby authorized to discharge industrial wastewater from the above identified facility into the DELCORA sewer system in accordance with effluent limitations, monitoring requirements, and other conditions set forth in this permit.

All discharges authorized herein shall be consistent with the terms and conditions of this permit. The discharge of any pollutant identified in this permit more frequently than or at a level in excess of that authorized shall constitute a violation of the permit.

This permit will be reopened and modified by DELCORA to incorporate any new or revised Federal, State, or Local Pretreatment Standards or requirements. Modified permits will be reissued according to Section 321 of Resolution No. 2011-04.

This permit shall become effective on **January 1, 2016** and shall expire at midnight on **December 31, 2019**.

The Permittee shall not discharge after the date of expiration. If the Permittee wishes to continue to discharge after this expiration date, an application must be filed for reissuing of this permit in accordance with the requirement of Section 319 of Resolution No. 2011-04, a minimum of 180 days prior to the expiration date.



Signature

Executive Director
Title

Robert J. Willert
Name (Typed)

12-29-15
Date

ADMINISTRATION
☐ 610-876-5523
☐ FAX: 610-876-2728

CUSTOMER SERVICE/BILLING
☐ 610-876-5526
☐ FAX: 610-876-1460

PURCHASING & STORES
☐ 610-876-5523
☐ FAX: 610-497-7959

PLANT & MAINTENANCE
☐ 610-876-5523
☐ FAX: 610-497-7950

Total Suspended Solids (TSS). The total matter in water, wastewater or other liquids, and which is retained by a laboratory filtering, expressed in terms of weight and concentration [milligrams per liter (mg/L)].

TKN. Total Kjeldahl Nitrogen.

TOX. Total halogenated organics as listed in Appendix A of 40 CFR 136.

TPH. Total Petroleum Hydrocarbons.

All terms used in this permit which are not defined in this section are taken to have the same meaning as that in the DELCORA Standards, Rules, and Regulations of 2011, DELCORA Resolution No. 2011-04.

PART II – EFFLUENT LIMITATIONS

A. Outfall(s)

During the period of **January 1, 2016 to December 31, 2019** the Permittee is authorized to discharge processed wastewater from **tank water draws, boiler blow-down and other activities related to the transfer of crude oil** to the DELCORA sewer system through the outfall(s) listed below:

OUTFALL	DESCRIPTION
001	Wastewater discharged from DC-4 separator before dilution with sanitary sewage, as shown in "Darby Creek Tank Farm" drawing submitted with the 2015 permit application

B. Outfall 001 Limitations

During the period of **January 1, 2016 to December 31, 2019** the process discharge(s) through Outfall **001** shall comply with all applicable Federal, State and Local Statutes, Ordinances and Regulations, including Resolution(s) No. 2013-12 and No. 2011-04 and the following effluent limitations:

PARAMETER	MONTHLY AVERAGE RATE	PEAK DAILY RATE	DAILY MAXIMUM (mg/L)	MONTHLY AVERAGE (mg/L)
Flow	60,000 GPD	200,000 GPD	--	
BOD ₅			(1)	
COD			(1)	
FOG			100	
pH			(2)	